



Verisure Sàrl

Company No: CHE-300.209.613
P.O Box 155
CH-1290 Versoix, Geneva
Switzerland

DECLARATION OF PERFORMANCE

According to Construction Products Regulation (EU) No 305/2011
Document number: DoP_GW-SD3

1. Unique identification code of the product-type:

Type GW-SD3 Smoke Alarm Devices

2. Type, batch, serial number or any other element allowing identification of the construction product as required by Article 11(4):

None

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems installed in and around buildings

4. Name, registered trade name or trademark and contact address of the manufacturer as required pursuant to Article 11(5):

Verisure Sàrl

P.O Box 155, CH-1290 Versoix, Geneva, Switzerland

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks in Article 12(2):

Verisure Sàrl

P.O Box 155, CH-1290 Versoix, Geneva, Switzerland

6. System(s) of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

BSI Assurance UK Limited Accreditation No. 0086

performed type testing and an inspection of the manufacturing plant and of factory production control under system I and issued following certificate of constancy of performance / certificate of conformity:

0086-CPR-669110

8. In case of declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see point 7



verisure
SMART ALARMS



Verisure Sàrl

Company No: CHE-300.209.613
P.O Box 155
CH-1290 Versoix, Geneva
Switzerland

9. Declared performance

Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire condition	Passed	EN14604:2005/AC:2008 Art: 4.12, 4.18, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.19, 5.20
Operational reliability	Passed	EN14604:2005/AC:2008 Art: 4.1, 4.2, 4.3, 4.4, 4.5, 4.6, 4.7, 4.8, 4.9, 4.10, 4.11, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22, 5.23, 5.24
Tolerance to supply voltage	Passed	EN14604:2005/AC:2008 Art: 5.21
Durability of operational reliability and response delay, temperature resistance	Passed	EN14604:2005/AC:2008 Art: 5.7, 5.8
Durability of operational reliability, vibration resistance	Passed	EN14604:2005/AC:2008 Art: 5.12, 5.13
Durability of operational reliability, humidity resistance	Passed	EN14604:2005/AC:2008 Art: 5.9
Durability of operational reliability, corrosion resistance	Passed	EN14604:2005/AC:2008 Art: 5.10
Durability of operational reliability, electrical stability	Passed	EN14604:2005/AC:2008 Art: 5.14

Remarks: The products covered by this standard are assumed to operate, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

(Signature): Austin Lally

Name: Austin Lally

Title: CEO

Place and date of issue: Versoix, August 28 2017